



February 6, 2009

SIOUX CHIEF MFG. CO., INC.
PRODUCT GROUP DIRECTOR
DONALD G. KUSMEC
P.O. BOX 397
PECULIAR MO 64078

Re: Description: FITTINGS, COPPER-ALTERNATE SYSTEM
Manufacturer: SIOUX CHIEF MFG. CO., INC.
Product Name: BRAZED SADDLE FLANGE JOINT
Model Number(s): 1/2" X 1/2" X 1/2" FOR TYPE L OR M; 3/4" X 3/4" X 3/4" FOR TYPE L OR M;
1" X 1" X 1" FOR TYPE L OR M;
Product File No: 20090055

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 84.30 (5) (a) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of February 2014.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This product may only be installed in aboveground water supply piping.

This approval supersedes the approval issued on February 7, 2004 under product file number 20040021.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20040021.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson
Plumbing Product Reviewer
Phone: 608-266-6742
Fax: 608-267-9566
E-mail: Jerry.Thompson@wi.gov